



#### NOTES:

1. This blowoff is to be used to facilitate removal of debris and sediment on City-financed (CIP) water line construction only unless expressly approved by the City Engineer for use on a private development project.
2. Blowoff size must be in accordance with AWWA flushing flow rates, but not less than 2-inches with 4-inches being the next approved size.
3. Contractor shall design blowoffs larger than 2-inch and shall submit design to Engineer for approval. Contractor shall include temporary enclosure in his/her design per this drawing when blowoff is in travelway.



City Of Beaverton

#### ENGINEERING DEPARTMENT

UTILITIES ENGINEER  
David A. Winship, P.E.

DATE  
6 - 10 - 04

DRAWN BY  
JCH - CPD

DRAWING NO.  
633

#### TEMPORARY BLOWOFF FOR CONSTRUCTION PURPOSES (ON CITY C.I.P. PROJECTS ONLY)